

**COMPARK FILING NO. 3, Amd 4**

**Comments from Scott Barnett - Mulhern MRE per email dated 6-28-17**

1. Also related to the 3<sup>rd</sup> Amendment, please work out the issue of irrigating the Tracts with NP water.

The plan is for the site to be irrigated by a combination of the non-potable water line and the 8" potable water line that runs through the site. After speaking with our irrigation specialist, there is some concern with sufficient water pressure from the NP line to irrigate the entire site. Extra pumps and equipment would be required. Therefore, we do not see this as a feasible option.

2. All of the SS and PW service lines are shown appropriately on both of these CD sets. We do not have the landscape plans as of yet, but meanwhile, while those are being completed, please ensure adequate spacing between trees and service lines in the front yards of these lots. Nothing directly over top, or within 5 feet.

Trees have been spaced adequately to accommodate service lines in the front yards.