

Group: FP 2ND 15
Type: IREA 15
Status: REVISIONS REQUIRED
Date Submitted: 6/2/2020
Date Due: 6/23/2020
Date Completed: 6/9/2020
Reviewer: Brooks Kaufman
Notes:

Comment response:

The note has been added to the plat. It is the last note shown on sheet 1 of the plat.

6/9/2020 9:58:40 AM The applicant will be required to add the note to the plat: ADD NOTE: MONUMENT SIGN, MASONARY FENCE COLUMNS WINDOW WELLS, DECKS, COUNTERFORTS,RETAINING WALLS AND THEIR COMPONENTS MAY NOT ENCROACH INTO UTILITY EASEMENTS.